



JEFFERSON PARISH

DEPARTMENT OF PURCHASING

CYNTHIA LEE SHENG
PARISH PRESIDENT

RENNY SIMNO
DIRECTOR

December 11, 2020

ADDENDUM # 1

Bid Number: 50-00132602

Bid Opening Date: December 17, 2020

Description of Bid: LABOR, MATERIALS, & EQUIPMENT NECESSARY TO INSTALL OUTDOOR FITNESS STATIONS AT WOODMERE WALKING TRACK & WESTMINSTER WALKING TRACK FOR THE JEFFERSON PARISH DEPARTMENT OF PARKS AND RECREATION

QUESTIONS AND ANSWERS:

Q1: Could you please help with a question regarding the sub-surface beneath the PIP rubber safety surfacing at Woodmere & Westminster? Would it be acceptable to use a compacted stone sub-base per NoFault's specifications instead of the concrete sub-base specified in the bid?

A1: No, that will not be acceptable.

Sincerely,

Melissa Ovalle

Melissa Ovalle
Buyer II

Bidders must acknowledge all addenda on the bid form. Bidder acknowledges receipt of this addendum on the bid form by indicating the addendum number listed above. Failure to list each addenda number on the bid form will result in bid rejection.

This addendum is a part of the contract documents and modifies the original bidding documents and specifications. The contents of this addendum shall be included in the contract documents. Changes made by this addendum shall take precedence over the documents of earlier date.

GENERAL GOVERNMENT BLDG. – 200 DERBIGNY ST., SUITE 4400, GRETN, LA 70053
OFFICE 504.364.2678

JOSEPH S. YENNI BLDG. – 1221 ELMWOOD PARK BLVD., SUITE 404, JEFFERSON, LA 70123
OFFICE 504.364.2678

EMAIL: PURCHASING@JEFFPARISH.NET WEBSITE: WWW.JEFFPARISH.NET